CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. Page 1 of 1 *3226-1581:101

CATEGORY: *Ceiling Dampers

LISTEE: Acme Engineering & Mfg. Corp., P.O. Box 978, Muskogee, OK 74402

Contact: Michael Almaguer (918) 684-0523 *FAX (918) 682-0134

DESIGN: Model RD-2, RD-2R, RD-2SB, RD-4, RD-8 and RD-521 ceiling dampers. Ceiling

> dampers function as a heat barrier in air handling penetrations through fire resistive ceilings and are intended to maintain the fire resistive integrity of the ceiling. Refer to

listee's data sheet for additional detailed product description and operational

considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a

manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

Listed as ceiling dampers for use in fire resistive floor-ceiling or roof-ceiling assemblies with a APPROVAL:

> restrained or unrestrained assembly rating of 3 hours or less. *Model RD-521 for use in UL Fire Resistance Directory floor-ceiling design Nos. L521, L546 and P522 only. *Refer to

listee's Installation Instruction Manual for details.

NOTE: 1. Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage

dampers.

2. Formerly *3225-1581:101

XLF: 3226-0368:104, Formerly 3225-0368:104

*Corrected 02-26-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

FEBRUARY 26, 2004 Date Issued: Listing Expires June 30, 2004

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager